

Heat pump sizing - open loop

Heat Loss and System Sizing - To achieve optimum long-term efficiency, we match the systems we install as closely as possible to the target heat load, i.e. the heat pump has to be capable of providing more heat (but not too much more) than the property will lose on the coldest of days, plus some extra capacity to take care of hot water generation. Many people feel happier with an amount of overcapacity in their heating system, however, this is seldom the best policy with ground source heat pumps and should only be considered if an extension to the area to be heated is a real and immediate possibility. Therefore, identifying the

25%

likely heat loss of a property is an important step in sizing a suitable heat pump system. The main factors involved in calculating heat loss are the materials and techniques used in the building of the property. Initially we use best-fit models to identify a suitable heat pump, but where detailed plans are available or a site survey has been carried out, we can derive a more accurate picture of likely heat loss. The Standard Assessment Procedure (SAP) report will be required to confirm the bespoke design for the system.

Example - The average pre 1980's 4-5 bedroom home that has good loft insulation and double glazing is likely to have an average heat loss in the order of 75W/m² (average heat loss per square metre of floor space). Such a property would be adequately served by a 17kW heat pump system. However, the same home constructed using the latest techniques and materials may have an average heat loss as low



as 40W/m² and therefore would be adequately served by an 8kW heat pump system.





Borehole design

Once the heat load of the property is known the flow rates required to support the heat pump can be finalized. Usually a full hydrogeological survey is undertaken to establish a borehole design capable of supporting the flow rates required by the heat pump and to give a clear indication as to whether there is enough water in the ground.



